

Equivalency Evaluation Report

Rule 61G2-3 F.A.C. | Report No. 2297-EER, Rev. 5 | Project No. 423-0610 | 1/6/23 | Page 1 of 2

Product Manufacturer

INNOVA PANEL, LLC
1541B North Powerline Road
Pompano Beach, FL, 330639

Product Name, Model and/or Description

Structural Insulated Panel
Plywood/MgO Face Sheets – Roof and Floor (IEBS0001)
OSB/MgO Face Sheets – Roof and Floor (IEBS0002)
MgO/MgO Face Sheets – Roof and Floor (IEBS0006)

Code: Current Edition of the Florida Building Code including 8th Edition (2023) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Performance Testing Standards: Performance testing was conducted to the following standards per the current Edition of the Florida Building and Residential Codes:

- ASTM E330-02
- TAS 202-94, Structural Loading only
- TAS 201-94, Impact
- TAS 203-94, Post-Impact Cyclic Loading

Test Reports: Testing conducted by Fenestration Testing Laboratory

- Test Report No. 13-5033/Lab No. 7321-03, dated 3/5/2014, signed and sealed by Marlin Brinson, FL PE License No. 60749, for Structural Insulated Panel – Plywood/MgO Face Sheets and Structural Insulated Panel – OSB/MgO Face Sheets.
- Test Report No. 13-5033/Lab No. 8447, dated 8/31/2015, signed and sealed by Idalmis Ortega, FL PE License No. 76905, for Structural Insulated Panel – MgO /MgO Face Sheets.

Performance Testing Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

The table below equates performance testing standard revision levels and compares them to the revision level in the 8th Edition (2023) FBC/FRC.

Standard Used in Performance Testing	Standard as Listed in 2023 FBC	Standard as Listed in 2023 FRC	Conclusion
ASTM E330-02	14	14	See below
TAS 201-1994	TAS 201-1994	TAS 201-1994	
TAS 202-1994	TAS 202-1994	TAS 202-1994	
TAS 203-1994	TAS 203-1994	TAS 203-1994	

Testing standards and methods employed and reported in the product approval documents are consistent with the requirements of the current edition of the Florida Building Code.




Equivalency Evaluation Report

Rule 61G2-3 F.A.C. | Report No. 2297-EER, Rev. 5 | Project No. 423-0610 | 1/6/23 | Page 2 of 2

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso

Date:
2024.02.15
16:21:50[®]
-05'00'

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752

