

Equivalency Evaluation Report

Report No. ACE-EER-1244, Rev. 0 | Project No. ACE-2026-150 | 8/18/26 | Page 1 of 2

Product Manufacturer

Sierra Pacific Windows
575 South Whelen Ave.
Medford, Wisconsin 54451

Product Name, Model and/or Description

FeelSafe & FeelSafe IG Monument Double Hung/Single Hung
Operating Window with Transom Window Stack with 1/4" x 5"
Aluminum Horizontal Plate Mull 82.63"W x 106.19"H Mull
Assembly

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation: Products covered by this evaluation include the following.

- FeelSafe & FeelSafe IG Monument Double Hung/Single Hung Operating Window with Transom Window Stack with 1/4" x 5" Aluminum Horizontal Plate Mull 82.63"W x 106.19"H Mull Assembly, Fin Installation with L-Clip and Screws at Mulls (shown on HURD0015)
- FeelSafe & FeelSafe IG Monument Double Hung/Single Hung Operating Window with Transom Window Stack with 1/4" x 5" Aluminum Horizontal Plate Mull 82.63"W x 106.19"H Mull Assembly, Screw Thru Frame & L-Clip Installation (shown on HURD0016)
- FeelSafe & FeelSafe IG Monument Double Hung/Single Hung Operating Window with Transom Window Stack with 1/4" x 5" Aluminum Horizontal Plate Mull 82.63"W x 106.19"H Mull Assembly, L-Clip Installation with Screws at Mulls (shown on HURD0017)

Product Testing and Certification:

- Element Materials Technology Test Report No. ESP015004P-1482 and associated laboratory drawings.
- Certification by WDMA
- Laminated Glazing Interlayers.
 - Eastman Chemical Company (MA) Saflex PVB Interlayer code conformance per the current issued Miami-Dade Notice of Acceptance. Eastman Chemical Company (MA) MD NOAs can be found [here](#).
- Materials
 - Window Frame Material: Ponderosa pine used in testing. Other wood species applicable for use with this product are those with a specific gravity of 0.43 and modulus of elasticity of 1,200,000 psi or greater. All wood is minimum Grade 2 milled by Hurd Windows & Doors to select.
 - Aluminum cladding (6063-T5 or T6).

Product Installation Instructions:

- PTC Drawing No. HURD0015 prepared by Robert J. Amoruso, PE, signed and sealed 8/18/26.
- PTC Drawing No. HURD0016 prepared by Robert J. Amoruso, PE, signed and sealed 8/18/26.
- PTC Drawing No. HURD0017 prepared by Robert J. Amoruso, PE, signed and sealed 8/18/26.

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation Report

Report No. ACE-EER-1244, Rev. 0 | Project No. ACE-2026-150 | 8/18/26 | Page 2 of 2

Testing Equivalency Evaluation:

In accordance with Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards the following equivalency evaluation is conducted. Testing referenced above was conducted to the following.

- TAS 201 – 1994
- TAS 202 – 1994
- TAS 203 – 1994

9th Edition (2026) Florida Building and/or Residential Code refer to the following.


- TAS 201 – 1994
- TAS 202 – 1994
- TAS 203 – 1994

Based upon my review of the testing referenced above, the requirements of testing of the 9th Edition (2026) Florida Building and/or Residential Code have been met.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso
Date:
2026.09.11
14:52:04
-04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com