



## PRI Construction Materials Technologies LLC

6412 Badger Drive  
Tampa, FL 33610  
813.621.5777  
<https://www.pri-group.com/>

March 27, 2019

Dear Sir/Madam,

PRI-CMT issued Laboratory Test Reports utilized to support FL17566 for Central States Manufacturing, Inc. This letter serves to establish compliance of legacy test reports to the Florida Building Code, 6<sup>th</sup> Edition (2017).

### **FL17566 – Central Snap**

Applicable product specifications: UL 580 and UL 1897

- FBC 2017 referenced standard year: UL 580-06 and UL 1897-12
- Test Report: PRI Project/Report Number FAE-016-02-01 states testing conforms to UL 580-06 and UL 1897-04
- Action: UL 1897-12 was reapproved in 2012 with no substantive modifications impacting report FAE-016-02-01; no actions required.
- Conclusion: Compliance to FBC 2017 established.

Statement of Independence: PRI Construction Materials Technologies and/or Zachary R. Priest, FL P.E. do not have nor plan to acquire a financial interest in any company manufacturing or distributing products for which the test reports are issued.

Signed:

A handwritten signature in black ink, appearing to read 'Zachary R. Priest', written over a horizontal line.

Zachary R. Priest  
Florida Registered Professional Engineer  
PE No. 74021