

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

EQUIVALENCE OF PRODUCT STANDARDS

PRODUCT: KAWNEER 2500 PG WALL CURTAINWALL SYSTEM
LARGE AND SMALL MISSILE (LEVEL D, WIND ZONE 3)

MANUFACTURER: KAWNEER, INC.
5555 WINDWARD PARKWAY, SUITE 220
ALPHARETTA, GA 30004

Product Description:

The Kawneer 2500 PG Wall is a unitized aluminum curtainwall system, as detailed in Installation Drawing 2500-PG-WZ3.

Equivalent Standards:

ASTM E1886-05 to ASTM E1886-19
ASTM E1996-12a to ASTM E1996-20
ASTM E283-04, E330/E330M-14, E331-00, E1886-05, and E1996-12a to AAMA 501-25.


Assessment:

The product indicated above has been tested to ASTM E283-04, E330/E330M-14, E331-00, E1886-05, and E1996-12a. I have determined that for the indicated product as defined in the indicated Installation Instructions and Evaluation Report, that ASTM E1886-05 is equivalent to ASTM E1886-19, ASTM E1996-12a is equivalent to ASTM E1996-20, and ASTM E283-04, E330/E330M-14, E331-00, E1886-05, & E1996-12a are equivalent to AAMA 501-25 as referenced in the 9th Edition (2026) Florida Building Code.

If you have any questions concerning this equivalency statement or need more information please contact me.

Thank you,


Scott Wolters
FL PE# 62354
OCT 18 2026



Digitally signed
by Scott Wolters
Date: 2026.10.18
23:07:38 -04'00'

SPECIALIZING IN IMPACT RESISTANT CURTAINWALLS, STOREFRONTS, & WINDOWS