



August 19, 2026

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399

Regarding: OldCastle Building Envelope

Reliance Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.1 – EX 26-101121
Reliance IG SS Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.2 – EX 26-101122
Reliance TC IG Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.3 – EX 26-101123
Reliance SS Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.4 – EX 26-101124
Reliance TC Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.5 – EX 26-101125
Reliance LT Curtain Wall System (Non-impact/Non-HVHZ)
FL #17691.6 – EX 26-101126


To Whom It May Concern:

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the Florida Building Code Ninth Edition (2026); however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above referenced building code.

OldCastle Building Envelope - FL #17691.1 Thru FL #17691.6

Code Title	Tests Performed according to:	Current Equivalent Standard
Methods of Test for Exterior Walls	AAMA 501-05	AAMA 501-25
Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain Walls by Uniform Static Air Pressure Difference	ASTM E331-00	ASTM E331-00 (2023)
Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows Curtain Walls, and Doors Under Specified Pressure Difference Across the Specimen	ASTM E283-04	ASTM E283-19
Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference	ASTM E330-02	ASTM E330-14 (2021)

Respectfully,



Digitally signed
by Frank
Bennardo
Date: 2026.08.19
16:32:19 -04'00'

Frank L. Bennardo, P.E.
ENGINEERING EXPRESS®
#PE0046549 | Cert. Auth. 9885

*PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED. SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

***FOR FLORIDA STATEWIDE PRODUCT APPROVALS (FSAs) REGISTERED & APPROVED WITH THE STATE OF FLORIDA:** ORIGINAL, SEALED COPIES OF APPROVED FLORIDA PRODUCT APPROVALS ARE NOT REQUIRED FOR PERMIT. SEE [ECALC.IO/SEAL](https://ecalculator.com/SEAL) TO LEARN MORE.