



Rice Engineering, Inc.
Certificate of Authorization #9090

May 24, 2021

Engineering Equivalency Report
Report No.: REI R20-09-155

Prepared by:

Wayne Helmila P.E.

Florida Professional Engineer License No. 59092

1. Manufacturer:

Pottorff
5101 Blue Mound Road
Fort Worth, TX 76106

2. Product Line:

ECD-545-MD

3. Product Description:

Extruded Aluminum Louver

4. Code Compliance:

The requirements of ANSI/AMCA Standard 550-15 meet or exceed the requirements of AMCA Standard 550-09 for the purpose of evaluating the Pottorff ECD-545-MD Extruded Aluminum Louver for High Velocity Wind Driven Rain Resistance per the 7th Edition (2020) Florida Building Code.

5. Test Standard:


Testing: AMCA 550-15
Intertek, Test Report No. I8042.02-801-44 RO dated 08-28-2018

6. Equivalency of Standard:

Testing standard AMCA 550-15 is equivalent to testing standard AMCA 550-09 for the purpose of the use of this product.

7. Certification of Independence

Wayne Helmila, P.E. does not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, Wayne Helmila, P.E. does not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



05/24/2021

COA: 9090

RICE

ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092

05/24/2021

Wayne Helmila,
P.E. Florida license
No. 59092
Rice Engineering, Inc.
Certificate of Authorization #9090

