


October 10, 2023

Cornell Iron Works
24 Elmwood Ave
Mountain Top, PA 18707
Attn: Christopher Rebarchak



RE: Equivalent Standards FL19075

Project #TCCI-FBC2023-FL: Exterior Rolling Overhead Doors
(CP0005 Slats)

Includes non-insulated rated for up to 50FPS impact velocity conditions.

To whom it may concern:

ASTM E330-02 is referenced in the evaluation report in regards to Research Slat Tests, conducted by Architectural Testing Inc., but it is not the current code year version listed in Florida Building Code 2023. ASTM E330-02 is equivalent to the current version ASTM E330-14 that is listed in the Florida Building Code 2023.

Should you have further questions regarding this, please feel free to contact me directly at 703-988-2350.

Best Regards,

Shawn Kelley



Expires: 2/28/25

Shawn P. Kelley, P.E.

Principal, Structural Engineer
moment ENGINEERING + DESIGN

www.mseglc.com

Phone: 703-606-5357

Email: spkelley@mseglc.com