

398 East Dania Beach Suite 338 Dania Beach, FL 33004 954.399.8478 PH 954.744.4738 FX contact@buildingdrops.com

December 1, 2016

To: Whom it May Concern

From: Hermes F. Norero, P.E.

Florida P.E. No. 73778

Manufacturer: Continental Glass Systems, LLC

325 W. 74th Place Hialeah, FL 33014

Re: Equivalence of Test Standards

This document shall serve to state that the <u>Continental Glass Systems, LLC products in question</u> comply with Chapter 17 & 24 of the 5th Edition Florida Building Code for testing in accordance with AAMA 501-05 "Methods of Tests for Exterior Walls".

Further, the testing on this product complies with the requirements specified within the AAMA 501-05 standard, as required by the Florida Building Code. This standard is listed under Chapter 35 of the current Florida Building Code and titled "Methods of Tests for Exterior Walls".

At a minimum, AAMA 501-05 requires exterior wall systems be tested to ASTM E283, ASTM E330 and ASTM E331 test standards.

Continental Glass Systems, LLC has successfully tested their products to ASTM E283, ASTM E330, and ASTM E331 in accordance with the test requirements set forth within <u>TAS 202-94</u>. All test methods and procedures may be considered equivalent or better than those in AAMA 501-05.

All test results meet or exceed requirements of the current Florida Building Code.

Respectfully submitted

No 73778

NO 73778

PROPRIDE

Hermes Norero, P.E.

Florida Registered Professional Engineer #73778

Certification of Independence:

Please note that I do not have nor will I acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will I acquire a financial interest in any other entity involved in the approval process of the listed product(s).