



ICC PEI LLC
58640 SR 15
Goshen, IN 46528
t: 574-533-0337
f: 574-533-9736
www.p-e-i.com

August 25, 2021

Stephanie Floyd
PEI-ES
58640 SR 15
Goshen, IN 46528

Subject: Test Standard Revision Verification

Dear Mrs. Floyd;

I have reviewed the test standards listed in your e-mail dated 8/25/21 for changes/differences due to the versions cited in our test reports versus the version cited in the 2020 FBC. Specifically, this pertains to the product listed under PEI-ES Product Evaluation Report PER-17111.

1. **ASTM DD7032-14 or D7032-17** - I found no differences from the '14 to '17 version that would affect the test values reported for the siding products listed in PER-17111.
2. **ASTM G154-12a or G154-16** - I found no differences from the '12a to '16 version that would affect the test values reported for the siding products listed in PER-17111.

Please feel free to contact me with any questions or concerns at 574-533-0337 ext. 144 or via e-mail at jholdeman@p-e-i.com.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jason R. Holdeman', written over a horizontal line.

Jason R. Holdeman
Director of Testing