



CIVIL • STRUCTURAL • MARINE
COASTAL • GEOTECHNICAL

www.meaengineers.com


EQUIVALENCE OF PRODUCT STANDARDS

REPORT NO.: 20-0808
DATE: October 3, 2020
PRODUCT CATEGORY: Impact Protective Systems
PRODUCT SUB-CATEGORY: Operable
PRODUCT NAME: Greentek Hybrid Roll-up Shutter System
MANUFACTURER: Ultratek Worldwide Inc.
3801 N. Washington Blvd.
Sarasota, FL 34234

Dear Sir (Madam):

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the 2020 Seventh edition of the Florida Building Code; however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above referenced building code.

Code Title	Tests Performed According to	Current Equivalent Standard
Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials	ASTM E1886-02	ASTM E1886-12
Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes	ASTM E1996-03	ASTM E1996-17



John H. Kampmann Jr., PE
Florida License No.: 47516
Date:

THIS ITEM HAS BEEN DIGITALLY
SIGNED AND SEALED BY JOHN
HENRY KAMPMANN JR. ON THE DATE
ADJACENT TO THE SEAL.

PRINTED COPIES OF THIS
DOCUMENT ARE NOT CONSIDERED
SIGNED AND SEALED AND THE
SIGNATURE MUST BE VERIFIED ON
ANY ELECTRONIC COPIES.

Digitally signed by John Henry
Kampmann Jr.

DN: c=US, st=Florida,
l=Sarasota, o=John Henry
Kampmann Jr., cn=John Henry
Kampmann Jr.,
email=jkampmann@meaengineers.com

Date: 2020.10.12 12:15:17
-04'00'

2352 APPALOOSA CIRCLE, SARASOTA, FL 34240 **PHONE** (941) 922-3854
FAX (941) 922-9564 **EMAIL** jkampmann@meaengineers.com