

December 8, 2020

Equivalence of Product Standards

Product Description:

Simonton Fixed Windows as indicated in Florida Product Approval FL228

Manufacturer:

Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

Equivalent Standards:

AAMA 506-08 and AAMA 506-16
ASTM E 1886-05 and ASTM E 1886-13a
ASTM E 1996-05/09 and ASTM E 1996-14a

Assessment:

The products indicated in the above-listed Florida Product Approval (FPA) has been tested and certified in various configurations in accordance with AAMA 506-08, ASTM E 1886-05, and ASTM E 1996-05/09. I have determined that for the indicated products as defined in the Certifications, Installation Instructions, and Evaluation Reports in the above-listed FPA, the pertinent air/water/structural/impact/cyclic testing performed as indicated above is equivalent to the testing performed for AAMA 506-16, ASTM E 1886-13a, and ASTM E 1996-14a, respectively, as referenced in the 7th Edition (2020) Florida Building Code.



12/8/2020
Lucas A. Turner, P.E.
FL P.E. 58201