



February 12th, 2021

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399


Regarding: Building Envelope Systems, Inc.
Series 7500 Curtain Wall (LMI/SMI) Aluminum Curtain Wall
Missile Level "D"

To Whom It May Concern:

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the Florida Building Code Seventh Edition (2020); however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above referenced building code.

Code Title	Tests Performed according to:	Current Equivalent Standard
Methods of Test for Exterior Walls	AAMA 501-05	AAMA 501-15
Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows Curtain Walls, and Doors Under Specified Pressure Difference Across the Specimen	ASTM E283-04	ASTM E283-12
Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain Walls by Uniform Static Air Pressure Difference	ASTM E331-00	ASTM E331-09

Respectfully,



02/12/2021

Frank L. Bennardo, P.E.
ENGINEERING EXPRESS®
#PE0046549 | Cert. Auth. 9885