

Dolby Engineering
1185 Whisper Cove Drive
Buford, GA 30518
470-655-6475

August 11, 2026

Equivalence of Product Standards


Manufacturer:

Kawneer Company
555 Guthridge Court
Norcross, Georgia 30092

Kawneer Curtain Wall product 1600 Wall System 1 was tested under standards that met AAMA 501 2015 edition *Methods of Tests for Exterior Walls*. Reviewing AAMA 501 2025 edition *Methods of Tests for Exterior Walls* referenced in the 9th Edition (2026) Florida Building Code, it was determined the product testing is equivalent to those performed under AAMA 501 2015. Also testing conducted under TAS 201, TAS 202, and TAS 203 and ASTM E1996-17 is still applicable in the 9th Edition (2026) Florida Building Code.

Conclusions:

AAMA 501-05 is equivalent to AAMA 501-25
TAS 201-94, TAS 202-94, TAS 203-94 is current
ASTM E1996-17 is applicable



A handwritten signature in cursive script that reads "Tanya A. Dolby".

08/12/2026 10:25 AM

Tanya A. Dolby, P.E.
FL P.E. 93536