

July 9, 2021

Jamie Moore
Insulfoam, a Division of Carlisle Construction Materials, LLC.
17001 Fish Point Road
Prior Lake, Minnesota 55372

RE: Equivalence of Published Versions of ASTM E84

Dear Mr. Moore:

At your request, I have reviewed an ASTM test method standard to evaluate its equivalence to the same test method standard but with a different publication date as referenced by the Florida Building Code. Specifically, I am comparing:

ASTM E84-13 *Standard Test Method for Surface Burning Characteristics of Building Materials*
to
ASTM E84-16 *Standard Test Method for Surface Burning Characteristics of Building Materials*.

Our laboratory in York, Pennsylvania, is accredited to perform the above-referenced test methods. I have reviewed and compared the above-referenced test method standards, and it is my professional opinion that the test method standards are equivalent.

Specific changes include addition of new reference standards for extended duration burns and mounting of specific products as well as general editorial changes to the standard.

ARCHITECTURAL TESTING, INC.




Digitally Signed by: Daniel Craig Culbert

Daniel C. Culbert, P.E.
Engineer Team Leader

DCC:dcc/ajm

cc: M4439.01-122-34
Florida COA: 29274



2021.07.09 16:40:10 -04'00'