

October 18, 2023

Mr. Barry Dyble
Crown Building Products of Florida, LLC
6018 SW Highway 72
Arcadia, FL 34266

RE: EQUIVALENCE OF PUBLISHED AND ADOPTED VERSION OF ASTM C67

Mr. Dyble:

Product testing performed at American Test Lab of South Florida may be deemed noncompliant to the 2020 Florida Building Code because the testing was performed to a version of the ASTM C67 specification that is not a referenced standard in the code. This issue occurs frequently in the testing and certification industry as there are several building codes or recognized voluntary standards that unfortunately utilize different reference standards.

The issue at hand is whether the testing performed to ASTM C67-08 at the American Test Lab of South Florida is equivalent to the referenced ASTM C67-18 standard. I have reviewed both ASTM specifications and have determined that the testing performed to ASTM C67-08 satisfies all requirements of ASTM C67-18.

Please contact me should you require additional information regarding this issue.

Sincerely

Joshua Royce, P.E.
FL PE 68180