

Equivalency Evaluation Report

Report No. ACE-EER-1227, Rev. 0 | Project No. ACE-2025-127 | 8/4/26 | Page 1 of 2

Product Manufacturer

Renaissance Windows and Doors
13340 International Parkway
Jacksonville, FL 32218

Product Name, Model and/or Description

Series 8500 Vinyl Single Hung Window
Series 8600 Vinyl Single Hung Window

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation; Test Report No.; and Installation Drawing No.:

- Series 8500 Vinyl Single Hung Window
 - Architectural Testing Inc. Test Report No. 02-48976.02 to AAMA/NWWDA 101/I.S. 2-97 for 44x84 SH Window at 40 psf DP.
 - Architectural Testing Inc. Test Report No. 02-48976.01 to AAMA/NWWDA 101/I.S. 2-97 for 48x84 SH Window at 25 psf DP.
 - Drawing No. RWD0001, A, dated 8/4/26, signed and sealed by Robert J. Amoruso, Renaissance Windows and Doors Series 8500 Single Hung Window – Installation Anchorage Details.
- Series 8600 Vinyl Single Hung Window
 - Architectural Testing Inc. Test Report No. 02-51842.01 to AAMA/NWWDA 101/I.S. 2-97 for 44x84 SH Window at 45 psf DP.
 - Architectural Testing Inc. Test Report No. 02-51843.01 to AAMA/NWWDA 101/I.S. 2-97 for 44x72 SH Window at 50 psf DP.
 - Architectural Testing Inc. Test Report No. 02-51844.01 to AAMA/NWWDA 101/I.S. 2-97 for 36x84 SH Window at 55 psf DP.
 - Drawing No. RWD0007, Rev. A, dated 8/4/26, signed and sealed by Robert J. Amoruso, Renaissance Windows and Doors Series 8600 Single Hung Window – Installation Anchorage Details.

Performance Standards (used in testing):

- AAMA/NWWDA 101/I.S. 2-97, Voluntary Specifications for Aluminum, Vinyl (PVC) and Wood Windows and Glass Doors.

Equivalency Evaluation:

PERFORMANCE TESTING

The following table shows the performance standards used in testing and those in the current edition of the FBC used for this equivalency evaluation.

Standard Used in Testing/Evaluation		Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
AAMA/NWWDA 101/I.S. 2	97	11	11	See Evaluation Below

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation Report


Report No. ACE-EER-1227, Rev. 0 | Project No. ACE-2025-127 | 8/4/26 | Page 2 of 2

The AAMA reference standard(s) listed above and used in testing have been compared to their current revision level(s) in the 9th Edition (2026) Florida Building Code and found to be acceptable.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso

Date:
2026.08.14
05:11:48
-04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com