

EQUIVALENCY EVALUATION REPORT

Project No.: ACE-2026-157

Report No.: ACE-EER-2647, Rev. 3

Product Description:

- Formawall Dimension Series 2" Panels, 36" Module with 16" OC Support Spacing
- Formawall Dimension Series 2-1/2" Panels, 36" Module with 16" OC Support Spacing
- Formawall Dimension Series 3"T Panels, 36" Module with 16" OC Support Spacing

Product Manufacturer: Centria, 700 State Highway 121 Bypass, Suite 200, Lewisville, TX 75067

Code: 9th Edition (2026) Florida Building Code Including the High Velocity Hurricane Zone (HVHZ)

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

EQUIVALENCY EVALUATION:

Performance Testing Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

The table below equates performance testing standard revision levels and compares them to the revision level in the Current Edition of the FBC – Test Protocols.

Standard Used in Testing	Standard as Listed in Current Edition FBC/FRC
TAS 201-1994	TAS 201-1994
TAS 202-1994	TAS 202-1994
TAS 203-1994	TAS 203-1994
ASTM A370-10	Not in FBC or FRC
ASTM E84-16	ASTM E84-24
ASTM D1929-16	ASTM D1929-20

Based upon my review of the test reports, test methods and results as well as the standards used in testing, it was determined this product meets the testing requirements of the Current Edition of the Florida Building Code.

Design Standards Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

Fastener Design Safety factors used in engineering evaluation (Reference 3) are as prescribed in AISI S100-12. Fastener allowable is based on a safety factor of 3. Deflection limitation based on L/240 which exceeds L/120 required by the building code.

The 9th Edition (2026) Florida Building Code (FBC) requires AISI S100-16(2020) w/S2-20 to be used for cold-formed steel design.

The engineering evaluation in Reference 3 has been reviewed against the requirements of AISI S100-16(2020) w/S2-20 and found to be compliant with its requirements.

Therefore, this product and its engineering evaluations meet the requirements of the 9th Edition (2026) Florida Building Code (FBC).

REFERENCES & SUPPORTING DOCUMENTS:

1. Manufacturer's Installation Instructions:
 - a. INSTALL_FWDS_36in Panel_16 in Support O.C. Installation Details, Issued Date 2/5/20, Signed and Sealed by Robert J. Amoruso, P.E.
 - i. Formawall Dimension Series 2" (36" Maximum Panel Module with Supports 16" OC)
 - ii. Formawall Dimension Series /Formawall Dimension Graphix Series 2-1/2" (36" Maximum Panel Module with Supports 16" OC)
 - iii. Formawall Dimension Series /Formawall Dimension Graphix Series 3"T Panels (36" Maximum Panel Module with Supports 16" OC)
2. Testing
 - a. TAS 201, TAS 202 and TAS 203
 - i. Farabaugh Engineering and Testing Inc. Test Report No. T118-20, Dated 2/4/20, Signed and Sealed by Daniel G. Farabaugh, P.E. for Formawall Dimension Series 2", 36" Maximum Panel Module with 16" OC Support Spacing.
 - b. ASTM A370-10 Tensile Testing
 - i. Farabaugh Engineering and Testing Inc. Test Report No. T118-20, Dated 2/4/20, Signed and Sealed by Daniel G. Farabaugh, P.E. for 2" thick foam panel with 22 ga. fascia and 26 ga. liner.
 - c. ASTM E84-16 Flame Spread and Smoke Developed Index testing of foam core material HHFF 40519 (Huntsman Foam Core WR40519) in various thicknesses to envelope Formawall product.
 - i. Intertek Report No. F9712.07-121-24, dated 8/17/16, 2" foam.
 - ii. Intertek Report No. F9712.08-121-24, dated 8/17/16, 2" foam.
 - iii. Intertek Report No. F9712.09-121-24, dated 8/17/16, 2" foam.
 - iv. Intertek Report No. F9712.01-121-24, dated 8/3/16, 3" foam.
 - v. Intertek Report No. F9712.02-121-24, dated 8/3/16, 3" foam.
 - vi. Intertek Report No. F9712.03-121-24, dated 8/3/16, 3" foam.
 - d. ASTM D1929-16 Self-Ignition and Flash-Ignition Temperature testing of Huntsman Foam Core WR40519 material
 - i. Intertek Report No. F9652.03-106-31, dated 08/23/17
3. Reports and Calculations
 - a. Calculation No. ACE-CALC-2647, Anchorage Analysis - Formawall Dimension Series 2", 2-1/2" and 3"T Panels, Signed and Sealed by Robert J. Amoruso, P.E.
 - i. AISI S100-12 used in engineering evaluation.
4. Standards used in evaluation.
 - a. AISI S100-12, North American Specification for the Design of Cold-formed Steel Structural Members

- b. Metal Construction Association, Guidelines for Wall Panel, Preformed Metal Wall Specification Guidelines, 3rd Edition.
- 5. Standards required in the 9th Edition (2026) Florida Building Code.
 - a. AISI S100-16(2020) w/S2-20, North American Specification for the Design of Cold-formed Steel Structural Members

Certificate of Independence per Product
Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2026.09.22
11:30:19 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752