

Equivalency Evaluation Report

Report No. ACE-EER-1232, Rev. 0 | Project No. ACE-2025-127 | 8/4/263 | Page 1 of 2

<u>Product Manufacturer</u>	<u>Product Name, Model and/or Description</u>
Renaissance Windows and Doors 13340 International Parkway Jacksonville, FL 32218	Series 8400 Vinyl Sliding Glass Door – OX, XO, OXO, OXXO Series 9700 Vinyl Sliding Glass Door – XX, OX, XO Series 9700 Vinyl Sliding Glass Door – OXO, OXXO

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation: Products covered by this evaluation include the following.

- Series 8400 Vinyl Sliding Glass Door, Drawing No. RWD0024:
 - OX and XO
 - OXO
 - OXXO
- Series 9700 Vinyl Sliding Glass Door, Drawing No. RWD0019 and RWD0020:
 - OX and XO
 - XX
 - OXO
 - OXXO

Product Testing, Materials and Certification (as applicable):

- Series 8400 Vinyl Sliding Glass Door – OX, XO, OXO, OXXO, Drawing No. RWD0024
 - Intertek/ATI Inc. G5681-01-901-44-r0 (OX, 96x83 & 96x96 frame heights), dated 5/24/17, testing conduct to AAMA/WDMA/CSA 101/I.S.2/A440-08/11.
 - Intertek/ATI Inc. E9674-01-901-44-r0 (OXO, 130x84 frame height), dated 9/2/15, testing conduct to AAMA/WDMA/CSA 101/I.S.2/A440-08/11.
 - Intertek/ATI Inc. D4937-01-901-44-r0 (OXXO, 142x80 frame height), dated 4/3/14, testing conduct to AAMA/WDMA/CSA 101/I.S.2/A440-08.
- Series 9700 Vinyl Sliding Glass Door – XX, OX, XO, Drawing No. RWD0019 & Series 9700 Vinyl Sliding Glass Door – OXO, OXXO, Drawing No. RWD0020
 - Intertek/ATI Inc. E0597.03-550-18 (OX), dated 3/12/15, testing conduct to TAS 201-94, TAS 202-94 and TAS 203-94, signed and sealed by Shawn Collins, PE, (FL No. 70655).
 - Intertek/ATI Inc. E0597.04-550-18 (XX), dated 12/15/14, testing conduct to TAS 201-94, TAS 202-94 and TAS 203-94, signed and sealed by Shawn Collins, PE, (FL No. 70655)
 - Intertek/ATI Inc. E0597.02-550-18 (OXO), dated 12/15/14, testing conduct to TAS 201-94, TAS 202-94 and TAS 203-94, signed and sealed by Shawn Collins, PE, (FL No. 70655).
 - Intertek/ATI Inc. E0597.01-550-18 (OXXO), dated 12/15/14, testing conduct to TAS 201-94, TAS 202-94 and TAS 203-94, signed and sealed by Shawn Collins, PE, (FL No. 70655).

Equivalency Evaluation Report

Report No. ACE-EER-1232, Rev. 0 | Project No. ACE-2025-127 | 8/4/263 | Page 2 of 2

Equivalency Evaluation:

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
AAMA/WDMA/CSA 101/I.S.2/A440	08	11	11	See Evaluation Below
AAMA/WDMA/CSA 101/I.S.2/A440	11	11	11	Meets 9 th Edition (2026) FBC
TAS 201	94	94	94	See Evaluation Below
TAS 202	94	94	94	
TAS 203	94	94	94	


TAS 201, TAS 202 & TAS 203: It has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s).

The AAMA reference standard(s) listed above and used in testing have been compared to their current revision level(s) in the 9th Edition (2026) Florida Building Code and found to be acceptable.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2026.08.15
15:44:35 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com