



August 7, 2026

Product Approval Administrator  
DBPR Codes and Standards  
2601 Blair Stone Road  
Tallahassee, FL 32399

Regarding: American Shutter Systems Association, Inc.  
40mm Slat Bertha Roll-Up Hurricane Shutter – FL #32029.1 – EX #  
26-102875

To Whom It May Concern:


This office has reviewed test report(s) showing structural performance of the above-noted product(s). These test report(s) pertain to testing performed in accordance with the referenced standard(s) in the table shown below. The noted standard(s) are not adopted in the Florida Building Code Ninth Edition (2026); however, for the purpose of determining the performance of the product, the standard(s) are equivalent to the corresponding standard(s), which are adopted in the above-referenced building code.

| <b>Test Standard Title</b>                                                                                                                                                  | <b>Tests Performed According to:</b> | <b>Current Equivalent Standard in FBC 2026:</b> |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------|-------------------------------------------------|
| Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials | ASTM E1886-02 & 05                   | ASTM E1886 13a or 19                            |
| Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes                            | ASTM E1996-06                        | ASTM E1996-17, 20 or 23                         |
| Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference                                               | ASTM E330-02                         | E330/E330M—14 or 14(2021)                       |
| Impact test procedures                                                                                                                                                      | TAS 201-94                           | TAS 201-94                                      |

American Shutter Systems Association, Inc. – FL #32029

|                                                                                                                  |            |            |
|------------------------------------------------------------------------------------------------------------------|------------|------------|
| Criteria for testing impact & nonimpact resistant building envelope components using uniform static air pressure | TAS 202-94 | TAS 202-94 |
| Criteria for testing products subject to cyclic wind pressure loading                                            | TAS 203-94 | TAS 203-94 |

Respectfully,



Digitally signed

by Frank  
BennardoDate: 2026.08.17  
16:39:03 -04'00'

Frank Bennardo, P.E.

**ENGINEERING EXPRESS®**

PE# 0046549 | Cert. Auth. 9885

\*PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED. SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

**\*FOR FLORIDA STATEWIDE PRODUCT APPROVALS (FSAs) REGISTERED & APPROVED WITH THE**

**STATE OF FLORIDA:** ORIGINAL, SEALED COPIES OF APPROVED FLORIDA PRODUCT APPROVALS ARE NOT REQUIRED FOR PERMIT.

SEE [ECALC.IO/SEAL](https://ecalculator.com/seal) TO LEARN MORE.