

June 18, 2020

Equivalence of Product Standards

Product Description:

Mapes HBD/STY Panel Component to be used as Glazed-In Panels in Curtain Walls / Storefronts / Windows by Others, as indicated in Florida Product Approval FL32414

Manufacturer:

Mapes Panels, LLC, Lincoln, Nebraska

Equivalent Standards:

TAS 202-1994 and AAMA 501-2005

Assessment:

The product indicated in the above-listed Florida Product Approval (FPA) is a Panel Component intended for use in already-Approved systems as a glazed-in panel replacement for the Approved glazed-in panels. Representative single-panel specimens were tested in a curtain wall frame in accordance with TAS 201-94, TAS 202-94, and TAS 203-94. I have determined that for the indicated component product as defined in the Installation Instructions and Evaluation Report in the above-listed FPA, the air/water/structural testing performed for TAS 202-94 meets or exceeds the requirements of the three baseline required tests performed for AAMA 501-05 as referenced in the 6th Edition (2017) Florida Building Code, therefore for the purposes of this FPA the standards are equivalent.

22

6/18/2020
Lucas A. Turner, P.E.
FL P.E. 58201

