



August 21st, 2023

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399


Regarding: Oldcastle Building Envelope
Reliance StormMax Dry Glazed Aluminum Curtainwall System – Large Missile Impact – FL# 33108.1
Reliance StormMax Wet Glazed Aluminum Curtainwall System – Large Missile Impact – FL# 33108.2
Reliance StormMax SSG Aluminum Curtainwall System – Large and Small Missile Impact – FL# 33108.3
Reliance StormMax High Performance Curtainwall System – Large Missile Impact – Level “D” & “E” – FL# 33108.4

To Whom It May Concern:

This office has reviewed test reports showing the structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the Florida Building Code 8th Edition (2023); however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above-referenced building code.

Code Title	Tests Performed according to:	Current Equivalent Standard
Methods of Test for Exterior Walls	AAMA 501-05	AAMA 501-15
Test Method for Water Penetration of Exterior Windows, Skylights, Doors and Curtain Walls by Uniform Static Air Pressure Difference	ASTM E331-00	ASTM E331-09
Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows Curtain Walls, and Doors Under Specified Pressure Difference Across the Specimen	ASTM E283-04	ASTM E283-12
Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials	ASTM 1886	ASTM 1886-13
Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference	ASTM E330-00	ASTM E330-14

Respectfully,



Frank L. Bennardo, P.E.
ENGINEERING EXPRESS®
#PE0046549 | Cert. Auth. 9885