

Equivalency Evaluation Report

Rule 61G20 F.A.C. | Report No. EER-ACE-1037, Rev. 2 | ACE-2023-114 | 12/8/23 | Page 1 of 2

Product Manufacturer

Eco Glass, LLC
144 Hope Street
Longwood, FL 32750

Product Name, Model, Series and/or Description

Series S-7500 Sliding Glass Door (OXXO)

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Methods:

- Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Testing and Certification: National Certified Testing Laboratories, 8350 Parkline Blvd., Orlando, FL 32809

- Series S-7500 Sliding Glass Door
 - AI-04220-C1, dated 6/25/2014 to AAMA/WDMA/CSA 101/I.S. 1/A440-08 & 17
 - OXXO tested. XO, OX, OXO, XOO, OOX, XXO, OXX and OXO enveloped.
 - Certification – NAMI
 - NI015003
 - Waiver of Retest No. W-1971

Product Test Standards:

- AAMA/WDMA/CSA 101/I.S. 2/A440-08


Equivalency Evaluation of AAMA/WDMA/CSA 101/I.S. 2/A440-08 Performance Testing to AAMA/WDMA/CSA 101/I.S. 2/A440-17.

- Performance testing and associated results to AAMA/WDMA/CSA 101/I.S. 2/A440-08 was compared to the requirements of AAMA/WDMA/CSA 101/I.S. 2/A440-17. Based on that comparison, it was determined that the testing methods and results documented in Test Report No. AI-04220-C1 are equivalent to AAMA/WDMA/CSA 101/I.S. 2/A440-17.
- A Waiver of Retest evaluation was completed by the certification entity, NAMI, and determined that testing methods and results documented in Test Report No. AI-04220-C1 are equivalent to AAMA/WDMA/CSA 101/I.S. 2/A440-17.
- Therefore, Series S-7500 SGD meets the requirements of AAMA/WDMA/CSA 101/I.S. 2/A440-17.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E. does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Digitally signed by
Robert J Amoruso
Date: 2023.12.08
15:57:42 -05'00'