

Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2696-EER, Rev. 1 | Project No. 422-0902 | 6/14/23 | Page 1 of 2

Product Manufacturer

CertainTeed Gypsum Inc.
20 Moores Rd.
Malvern, PA 19355

Product Series, Model and/or Description

1/2" and 5/8" GlasRoc Sheathing

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Category: Panel Walls

Product Sub-Category: Siding

Performance Testing Standards:

- ASTM C1177/C1177 M-08
- ASTM E330-02

Product Testing:

- 1/2" GlasRoc Sheathing
 - Progressive Engineering Inc. Report No. 2010-1148(A), dated 10/21/2010, 1/2" GlasRoc Sheathing to ASTM C1177/C1177 M-08
 - HTL Report No. 0554-0906-09, testing to ASTM E330-02.
- 5/8" GlasRoc Sheathing
 - Progressive Engineering Inc. Report No. 2010-1148(B), dated 10/21/2010, 5/8" GlasRoc Sheathing to ASTM C1177/C1177 M-08
 - HTL Report No. 0554-0906-09, testing to ASTM E330-02.

Equivalency Evaluation:

PERFORMANCE TESTING

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standards Used in Testing		Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
ASTM C1177/C1177 M	08	17	17	See Evaluation Below
ASTM E330	02	14	14	

The above current FBC code-referenced performance standards were reviewed against the revision level of the standards employed in testing and found to be equivalent. Therefore, all testing is in conformance with the Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code – Building and Residential Volumes and Test Protocols.




Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2696-EER, Rev. 1 | Project No. 422-0902 | 6/14/23 | Page 2 of 2

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2023.06.22
15:59:04 -04'00'

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752

