

Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2702 | Project No. 419-0404 | 12/17/20 | Page 1 of 1

Product Manufacturer

EFCO CORPORATION
1000 County Road
Monett, Missouri 65708

Product Name, Model and/or Description

Series 2701 & 811I Casement Window - Outswing

Code: Current Edition of the Florida Building Code including the 7th Edition (2020) Florida Building Code

Compliance Methods: Product Approval Rule 61G20-3.015(5)(d) – Equivalency of Standards

Product Name, Model and/or Designation, Performance Testing and Test Reports: Products covered by this evaluation include the following.

- Series 2701 & Casement Window - Outswing
 - Intertek/ATI Test Report No. L2083.01-801-18-R0, dated 9/21/20, Series 2701 Casement Window - Outswing, TAS 201, TAS 202 and TAS 203 testing.
 - PTC Product Design Group Drawing No. EFCO-030, dated 12/14/20, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752.
- Series 811I Casement Window - Outswing
 - Intertek/ATI Test Report No. L2087.01-801-18-R0, dated 9/21/20, Series 811I Casement Window - Outswing, TAS 201, TAS 202 and TAS 203 testing.
 - PTC Product Design Group Drawing No. EFCO-031, dated 12/14/20, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752.

Component Verification: Glazing Interlayers to 7th Edition (2020) Florida Building Code.

- Eastman Chemical Company (MA), Saflex Storm (formally including Vanceva brand name) is approved to the 7th Edition (2020) Florida Building Code. See MD Notice of Acceptance (NOA) [here](#).
- Kuraray American SentryGlas (SG) (formally including SentryGlas+ or SGP brand name) is approved to the 7th Edition (2020) Florida Building Code. See MD Notice of Acceptance (NOA) [here](#).


Performance Testing Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

- TAS 201/202/203-94 Testing Equivalency Evaluation – Test Report shown above.
 - Based upon review of testing conducted and reported in the test reports listed above, these products were tested in a manner consistent with the current versions of TAS 201, TAS 202 and TAS 203 and is therefore in compliance with the 7th Edition (2020) Florida Building Code.

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date: 2021.02.04
19:04:07 -05'00'

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752



PTC Product Design Group, LLC | PO Box 520775 | Longwood, FL 32752-0775
321-690-1788 | FBPE Certification of Authorization No. 25935