

September 2, 2021

## Equivalence of Product Standards

### Product Description:

Simonton Casement Window Series 08-08 / 08-09 / 08-10 / 08-20 w/ Safepoint Impact – Missile C, as indicated in Florida Product Approval FL39614

### Manufacturer:

Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

### Equivalent Standards:

AAMA 506-06/08 and AAMA 506-16

### Assessment:

The product indicated above has been tested (reports C9011.01-501-47-r0, by Architectural Testing, Inc., and NCTL-110-24283-1, by National Certified Testing Laboratories) and certified (AAMA/FGIA Certification CPD #19702) in accordance with AAMA 506-06/08. I have determined that for the indicated products as defined in the above-listed test reports, certification, and installation instructions drawing IN0593, the pertinent air/water/structural/impact/cyclic testing performed for AAMA 506-06/08 is equivalent to the testing performed for AAMA 506-16 as referenced in the 7<sup>th</sup> Edition (2020) Florida Building Code.



9/2/2021

Lucas A. Turner, P.E.

FL P.E. 58201