



CREEK

TECHNICAL SERVICES, LLC

Registry No. 29824

October 16, 2023

Mr. Tim McQuillen
VADA LLC c/o Johns Manville
717 17th Street
Denver, CO 80202

Re: Equivalence of UL 1897-12 and UL 1897-15

Dear Mr. McQuillen:

At your request, I have reviewed and evaluated the equivalence of UL1897-12 to UL1897-15 for compliance to the Florida Building Code, 8th Edition (2023).

FL39633 – VADA Vent

Applicable test method: UL 1897

- FBC 2023 references standard year: UL 1897-15
- PRI CMT Test Report Number 1742T0001 states testing conforms to UL 1897-12
- UL 1897-15 was reapproved in 2015 with no substantive modifications impacting Test Report 1742T0001
- Conclusion: Compliance with FBC 2023 is established.


Statement of Independence: CREEK Technical Services, LLC and/or Zachary R. Priest, FL P.E. do not have nor plan to acquire a financial interest in any company manufacturing or distributing products for which the these reports are issued.

Should you have any questions, please contact me at 813-480-3421.

Best Regards,


2023.10.16
14:12:24
-04'00'

Zachary R. Priest, P.E.
President



This item has been
digitally signed and
sealed by Zachary R.
Priest, PE, on 10/16/2023.

Printed copies of this
document are not
considered signed and
sealed and the signature
must be verified on any
electronic copies.