

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION PTAC, LLC
4720 NW 15 TH AVE UNIT 4A
FORT LAUDERDALE, FL 33309

PRODUCT
SERIES "NEVERLEAK" HURRICANE IMPACT PTAC LOUVER WITH
"NEVERLEAK" PTAC WALL SLEEVE ASSEMBLY
ALUMINUM LOUVER SYSTEM - LMI

UNIT 'A' TEST REPORT # ATLSF: 1110.01-21
MAX. FRAME SIZE: 42" X 16"
DESIGN PRESSURE: (MAX.) = -90/+90 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS
SEE PRODUCT APPROVAL \DRAWINGS TO COORDINATE ALLOWABLE DESIGN PRESSURES FOR SPECIFIC UNIT SIZES,
ANCHOR LOCATION COMBINATIONS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202 (STRUCTURAL ONLY)/TAS203)

UNIT A TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REORT DATE	ENGINEER
ASTM E-330 & TAS 202	UNIFORM STATIC AIR PRESSURE	ATL OF SOUTH FLORIDA	ATLSF: 1110.01-21	11/19/21	STEPHEN WARTNER, P.E. #54395

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

FBC 1626.5 AMCA 540 TAS 201 & TAS 203	LARGE MISSILE - LEVEL "D" IMPACT & CYCLIC	ATL OF SOUTH FLORIDA	ATLSF: 1110.01-21	11/19/21	STEPHEN WARTNER, P.E. #54395
AMCA550-15 (REV. 09-18)	TEST METHOD FOR HIGH VELOCITY WIND DRIVEN RAIN RESISTANT LOUVERS	INTERTEK, WPB	N2946.01-450-44-R0		VINU ABRAHAM, P.E.

PLEASE NOTE (1): TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501.
PLEASE NOTE (2): ASTM E330-02 IS EQUIVALENT TO ASTM E330-14

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT
CONFORMS TO THE REQUIREMENTS OF THE 2023/ 2026 FLORIDA BUILDING CODE

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2026.09.16
12:43:47 -04'00'

