

Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2745-EER, Rev. 0 | Project No. 423-0813 | 10/16/2023 | Page 1 of 1

Product Manufacturer

Lomanco, Inc.
2101 West Maim St.
Jacksonville, AR 72076

Product Name, Model and/or Description

Series OSV-40 Solar Vent and Panel

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Methods: Product Approval Rule 61G20-3.015(5)(d) – Equivalency of Standards

- Series OSV-40 Solar Vent and Panel
 - LOM0001, Rev. 0, dated 6/4/22, signed and sealed by James D Wells P.E., Lomanco Series OSV-40 Solar Vent and Panel
 - Construction Consulting Laboratory International. Test Report No. CCLI-012-001, dated 01/27/2012

Performance Standards (used in testing):

- ASTM E330-02, Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference.

Equivalency Evaluation:

The 8th Edition (2023) Florida Building Code – Building and Residential requires the following revision level for the product testing standard listed above.

- ASTM E330- 14, Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference

The code-referenced performance standard was reviewed against the testing performance standard and was found to be equivalent. Therefore, all testing is in conformance with the 8th Edition (2023) Florida Building Code – Building and Residential Volumes and Test Protocols.

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and James D Wells, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC James D Wells, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed by
James D Wells Jr
Date: 2023.10.16
17:41:21 -04'00'

Evaluated By:
James D Wells, P.E.
FL P.E. License Number 53616

This item has been electronically signed and sealed by James D. Wells, Jr., P.E. on 10/16/2023 using a Digital Signature. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

