

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

October 12, 2026

Mr. Robert Richardson
Amarr Garage Doors
165 Carriage Court
Winston-Salem, NC 27105

Re: ASTM E330, E1886 & E1996 comparisons
Project No. 26-001

Mr. Richardson:

The 9th Edition Florida Building Code (2026) refers to ASTM E330, E1886 and ASTM E1996 Standards. The adopted versions of these Standards are listed in Chapter 35 of the Building Code and Chapter 46 of the Residential Code as follows:


- ASTM E330-14(2021)
- ASTM E1886-13a or -19
- ASTM E1996-17 or -20 or -23

Some Amarr garage doors were tested to earlier versions of these Standards, as listed below:

- ASTM E330-02
- ASTM E1886-05 or -13 or -13a
- ASTM E1996-06, -09 or -12a

A review of these Standards shows that Amarr garage doors that were tested in accordance with earlier versions listed above will also meet the requirements of ASTM E330-14(2021), ASTM E1886-13a or -19, and/or ASTM E1996-17 or -20 or -23.

Sincerely,



Thomas L
Shelmerdine

Digitally signed by Thomas L
Shelmerdine
DN: c=US, o=Unaffiliated,
dnQualifier=A01410C0000019B469
BB84300125111, cn=Thomas L
Shelmerdine
Date: 2026.10.12 14:38:33 -04'00'

STRUCTURAL SOLUTIONS, P.A.*

Thomas L. Shelmerdine, PE
Florida PE #48579