

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

EQUIVALENCE OF PRODUCT STANDARDS

PRODUCT: SMITH BUILT MASTER RIB 29 Ga. STEEL ROOF PANEL

MANUFACTURER: SMITH BUILT METALS
1380 WEST PACES FERRY, SUITE 2110
ATLANTA, GA 30327

Product Description:

Master Rib 29 Ga. Steel Roof Panel, 3/4" Rib Height x 36" Wide, as described in Farbaugh Test Reports T212-19, T214-19, and T215-19.

Equivalent Standards:

UL1897-2012 to UL1897-2015

Assessment:

The products indicated above have been tested to UL1897-2012.. I have determined that for the indicated products as defined in the indicated test reports, that UL1897-2012 is equivalent to UL1897-2015, as referenced in the 8th Edition (2023) Florida Building Code.

Thank you,


Scott Wolters
FL PE# 62354
APR 18 2024

