

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

EQUIVALENCE OF PRODUCT STANDARDS

PRODUCT: C.T. WINDOWS T850 SERIES CURTAINWALL SYSTEM
(LARGE AND SMALL MISSILE, CAPTURED & SSG)

MANUFACTURER: C.T. WINDOWS, LLC
9195 BOGGY ROAD
ORLANDO, FL 32824

Product Description:

The C.T. Windows T850 Series Curtainwall System is a unitized aluminum curtainwall system, as detailed in Installation Drawings AAT1-23 and AAT2-24.

Equivalent Standards:

ASTM E1886-05 to ASTM E1886-19
ASTM E1886-12/13a to ASTM E1886-19
ASTM E1996-05/09 to ASTM E1996-20
ASTM E1996-12a/14a to ASTM E1996-20

Assessment:


The product indicated above has been tested to ASTM E1886-05, E1886-12/13a, E1996-05/09, and E1996-12a/14a. I have determined that for the indicated product as defined in the indicated Installation Instructions and Evaluation Reports, that ASTM E1886-05 and E1886-12/13a are equivalent to ASTM E1886-19, and ASTM E1996-05/09 and E1996-12a/14a are equivalent to ASTM E1996-20, as referenced in the 9th Edition (2026) Florida Building Code.

If you have any questions concerning this equivalency statement or need more information please contact me.

Thank you,



Scott Wolters
FL PE# 62354
SEP 06 2026



SPECIALIZING IN IMPACT-RESISTANT CURTAINWALLS, STOREFRONTS, & WINDOWS