



July 24, 2026

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399


Regarding: AV Composites
Foam Core Roof Panel – Panel Span Performance Evaluation
FL # 41965.1 – EX # 26-102970

To Whom It May Concern:

This office has reviewed test report(s) showing structural performance of the above-noted product(s). These test report(s) pertain to testing performed in accordance with the referenced standard(s) in the table shown below. The noted standard(s) are not adopted in the Florida Building Code Ninth Edition (2026); however, for the purpose of determining the performance of the product, the standard(s) are equivalent to the corresponding standard(s), which are adopted in the above-referenced building code.

Code Title	Tests Performed according to:	Current Equivalent Standard
Uniform load normal to full face, applied in increments with deflection recorded at each step. Increments, hold time, instrumentation, and deflection requirements meet or exceed E330. Safety factor not less than detailed in FBC 1709.3.	ASTM E72 - 05	ASTM E330/E330M
Standard Test Method for Conducting Transverse and Concentrated Load Tests on Panels Used in Floor and Roof Construction 3115.4.2	ASTM E2322 - 03	ASTM E2322 – 03 & (2015)

Respectfully,



Digitally signed by
Colby Bennardo
Date: 2026.07.31
13:43:14 -04'00'

Colby Bennardo, P.E.
ENGINEERING EXPRESS®
#PE 95197 | Cert. Auth. 9885