

EQUIVALENCY EVALUATION REPORT	
Project No.: ACE-2025-128	Report No.: ACE-EER-1199, Rev. 0

Product Description : Versa Vent Ridge Vent Material

Product Manufacturer: Hibco Plastics, Inc., P.O. Box 157, Yadkinville, NC 27055

Code Compliance Statement: This report evaluates the product(s) listed above to the requirements of FAC Product Approval Rule 61G20-3.005. This product complies with the requirements of the 9th Edition (2026) Florida Building Code including the High Velocity Hurricane Zone (HVHZ) per the product testing standards listed below.

Compliance Method: Product Approval Rule 61G20-3.015 – Equivalency of Standards

Documentation/References:

1. Drawings:
 - a. HIB0001, Rev. C, dated 7/22/2026, signed, and sealed by Robert J. Amoruso, Hibco Plastics, Inc. Versa Vent Ridge Vent Material
2. Test Reports.
 - a. ATI Test Report No. 54543.01-120-32 to TAS 100(A)-95, signed and sealed by Joseph A. Reed, PE.
 - b. ATI Test Report No. 60944.01-106-31 to ASTM D 1929-96, ASTM D 635-98, and ASTM D 2843-99, signed and sealed by Joseph A. Reed, PE.
3. Reports
 - a. Report No. ACE-EER-1199, Rev. 0, Equivalency Evaluation Report for Hibco Plastics, Inc. Versa Vent Ridge Vent Material, signed and sealed by Robert J. Amoruso.

Performance And Testing Standards Summary:

Reference 2 conducted testing to the following standard(s). See Reference 3 for Equivalency Evaluation of test procedures to the 9th Edition (2026) FBC/FRC.

1. TAS 100(A)-95, Test Procedure for Wind and Wind Driven Rain Resistance and/or Increased Windspeed Resistance of Soffit Ventilation Strip and Continuous or Intermittent Ventilation System Installed at the Ridge Area.
2. ASTM D 1929-96, Standard Test Method for Determining Ignition Temperature of Plastics.
3. ASTM D 635-98, Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position.
4. ASTM D 2843-99, Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics.

Product Conformance Evaluation to 9th Edition (2026) FBC/FRC:

Testing (Reference 2) was conducted to the following standards (as documented in Product Evaluation Report No. 2153 - Reference 3).

Standard	Year Used in Testing (Ref. 2)	Year Required by 9th Edition FBC and/or FRC
TAS 100(A)	95	23
ASTM D1929	1996	2020
ASTM D635	1998	2018
ASTM D2843	1999	2019

Based upon a review of TAS-100(A)-23, the current edition test protocol has not changed from that used in testing in any manner that would negate test results.

Based upon a review of (a) Chapter 35 of the 9th Edition (2026) Florida Building Codes and (b) Chapter 46 of the 9th Edition (2026) Florida Residential Codes the following is concluded.


- The testing standard revision levels listed above and used for testing of product(s) included in this evaluation have been compared to those currently listed in the 9th Edition (2026) Florida Building and Residential Codes. Based upon that review, it was determined that the test results documented in Reference 2 test reports demonstrate code compliance to the 9th Edition (2026) FBC/FRC regarding testing requirements, results reporting and results interpretation. No changes exist in the listed testing standards that would necessitate re-testing of the product(s) included in this evaluation.
- Testing standards listed above are all present in Chapter 35 of the 9th Edition (2026) Florida Building Code.

Therefore, all test standards listed above, and test results associated with this product are valid for and demonstrate compliance to the 9th Edition (2026) Florida Building Code and the 9th Edition (2026) Florida Residential Code as applicable.

**Certificate of Independence per Product
Approval Rule 61G20-3.009**

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2026.08.07
15:57:56 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752