

July 15, 2026

Mr. Bryan L. Sheaffer
Armstrong World Industries, Inc.
2500 Columbia Avenue
Bldg 5
Lancaster, PA 17603

Re: UL 580 Equivalence

Dear Mr. Sheaffer:

Intertek reviewed testing conducted under report T4244.01-109-44 issued 06/17/26. Testing was conducted per UL 580, 2009 with 2024 revisions, for Uplift Resistance of Roof Assemblies. The current UL 580 version in the 2023 Florida Building Code, 8th Edition is 2006 with 2018 revisions.

The testing method, test phase, time durations, pressures and classes are the same for both versions. Testing conducted on report T4244.01-109-44 under the 2009 with 2024 revisions is equivalent to what would be tested under the 2006 with 2018 revisions.

In conclusion, test report T4244.01-109-44 is equivalent to the UL 580, 2006 with 2018 revisions.


For INTERTEK-ATI:



Digitally Signed by: Tanya Dolby

Tanya Dolby, P.E.

Manager – Engineering Services
Building & Construction



2026.07.15 11:39:09 -04'00'