



NEMO | cert.

353 Christian Street, Unit #12b
Oxford, CT 06478
(475) 888-CERT (2378)

contact@nemocert.com

INSPECT

CERTIFY

EVALUATE

VALIDATE

QUALIFY

2026-07-08

RE: Equivalency of Product Standards for FPA, FL46943

To Whom It May Concern:

This letter serves to document the comparison of the following test standards, in support of the Florida Product Approval File No. FL46943, for compliance with the **8th Edition, Florida Building Code**.

TESTED STANDARD	2023 FBC, REFERENCED STANDARD
UL 1897-12	UL 1897-15

Review identified the following changes between the 2015 and 2015 versions, with no effect on the requirements or test procedures for the 10x10-ft wind uplift test.

1. Include clarification of conditions of acceptance and addition of 2x2-ft pull test and 5x9-ft wind uplift test methods.

Based on this comparison, the tested specimens in the following reports are compliant with UL 1897-15:

PRI 2581T0009 & 2581T0012

Please contact our office with any questions.

Prepared by:

Luis Cadena, EIT

Department Manager, Evaluations
Florida DBPR EVL13843 and VAL14335

CERTIFICATION OF INDEPENDENCE:

1. NEMO CERT, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO CERT, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. NEMO Evaluation Reports (NER) and NEMO validations are not, in any way, to be construed to mean or imply that NEMO CERT, LLC is the Designer of Record for any project on which the NER is/was used for permitting or design guidance. NERs and validations are not to be construed as representing any attributes not specifically listed, nor are NERs or validations to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by NEMO CERT, LLC, express or implied, as to any finding or other matter within its NERs or validations, or as to any product covered by the NERs or validations.

NEMO CERT, LLC
www.nemocert.com



ISO/IEC 17065



PCA-145



ISO/IEC 17020



AA-779