



December 18, 2024

Ms. Kristin Nolan
OLDCASTLE BUILDING ENVELOPE
509 Airport Road
Terrell, TX 75160

Your Ref: Coral FL600T Aluminum Storefront Systems
Florida Product Approval #47136
Our Ref: BE-5975


Dear Ms. Nolan:


I have reviewed the equivalency of test specifications AAMA 501-15 to ASTM E283, ASTM E330, ASTM E331, and TAS 202. In my opinion and with the intent of the Florida Building Code, the testing performed to ASTM E283, ASTM E330, ASTM E331, and TAS 202 satisfies the intent of the AAMA 501-15 standard. Thus, they can be deemed equivalent for the purpose of this evaluation for the Florida Building Code 8th Edition (2023).

Please feel free to contact me if you have any questions or require further information.

Sincerely,

BROADWAY ENGINEERING, P.A.


Elizabeth A. Broadway, P.E.
President
Florida Registration No. 38558
5975-FL600T-2.ltr.wpd/eah



This item has been electronically signed and sealed by Elizabeth A. Broadway, P.E. using a Digital Signature.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

.....
1335 W. Cass Street
Tampa, FL 33606
(813) 251-9244
Fax: 251-9330
www.broadway-eng.com
.....
CIVIL
MECHANICAL
STRUCTURAL
BUILDING DESIGN
.....