

EQUIVALENCY EVALUATION REPORT	
Project No. ACE-2024-138	Report No. EER-ACE-1115, Rev. 0

Product Description: CertainTeed Vinyl and Polypropylene Siding Products – Various

Product Manufacturer: CertainTeed LLC, 20 Moores Road, Malvern, PA 19355

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation: Products covered by this evaluation are listed in the following.

1. Product Certification Listing PCL – 0505, dated June 24, 2024, for Wolverine Vinyl Siding products are extruded, rigid PVC siding conforming to ASTM D3679, as exterior wall covering. Testing standards include:
 - a. ASTM D3679-21 Standard Specification for Rigid Poly (Vinyl Chloride) (PVC) Siding
 - b. ASTM E84-21a Standard Test Method for Surface Burning Characteristics of Building Materials
 - c. NFPA 268-22 Standard Test Method for Determining Ignitability of Exterior Wall Assemblies Using a Radiant Heat Energy Source
2. Product Certification Listing PCL – 0506, dated June 24, 2024, for Wolverine Polypropylene Siding products are molded, polypropylene siding conforming to ASTM D7254, as exterior wall covering. Testing standards include:
 - a. ASTM D7254-21 Standard Specification for Polypropylene (PP) Siding
 - b. NFPA 268-22 Standard Test Method for Determining Ignitability of Exterior Wall Assemblies Using a Radiant Heat Energy Source
3. Product Evaluation Report PER – 0507, dated August 12, 2024, for Wolverine Vinyl and Polypropylene Siding

Test Standard Equivalency Evaluation:

Certification Listing Ref. No.	Testing Standards Used		Testing Standards Required by the 8th Edition (2023) of the Florida Building Code		Comments
	Designation	Year	FBC	FRC	
PCL – 0505	ASTM D3679	21	17	17	See Evaluation Conclusion below.
	ASTM E84	21a	18b	18b	
	NFPA 268	22	17	---	
PCL – 0506	ASTM D7254	21	17	17	
	NFPA 268	22	17	---	

EQUIVALENCY EVALUATION REPORT	
Project No. ACE-2024-138	Report No. EER-ACE-1115, Rev. 0

Evaluation Conclusion:

Where ASTM revision level differs, the testing requirements of both documents have been evaluated to determine if any differences exist that may result in testing outcomes different if based on the revision level required in the Current Edition of the Florida Building Code.

Where NFPA revision level differs, the testing requirements of both documents have been evaluated to determine if any differences exist that may result in testing outcomes different if based on the revision level required in the Current Edition of the Florida Building Code.

It was determined that the evaluated product assembly testing is equivalent to the prescribed standards required by the 8th Edition (2023) Florida Building Code and Florida Residential Code

**Certificate of Independence per Product
Approval Rule 61G20-3.009**

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso

Date:
2024.12.12
12:15:57[®]
-05'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752