

August 14, 2023

Re: ASTM E330/E330M-14(2021)


To Whom It May Concern:

ASTM E330/E330M-14(2021) is referenced in Chapter 35 of the 9th Edition of the Florida Building Code (Building) (2026). A review of these documents shows that testing of garage doors conducted on accordance with ASTM E330-2002 can be considered at least equivalent to ASTM E330/E330M-14(2021).

James D. Wheeler, P. E.
Florida P.E. No. 91932

Jim Wheeler

Digitally signed by Jim Wheeler
Date: 2026.08.14 09:58:06
-04'00'



This document has been digitally signed and is valid without a physical signature. Third-party verification of the PDF can attest that the document has not been changed since it was signed. The printed document is just a copy and cannot be verified.

This document has been digitally signed and is valid without a physical signature. Third-party verification of the PDF can attest that the document has not been changed since it was signed. The printed document is just a copy and cannot be verified.