

August 12, 2020


Re: ASTM E330-2002, ANSI/DASMA 108-2005, ANSI/DASMA 108-2012 Equivalence

To Whom It May Concern:

ASTM E330-2014 and ANSI/DASMA 108-2012 are referenced in Chapter 35 of the 7E Florida Building Code (Building) (2020). A review of these documents shows that testing of garage doors conducted in accordance with ASTM E330-2002 can be considered at least equivalent to ANSI/DASMA 108-2012.

Likewise, a review of ANSI/DASMA 108-2005 and ANSI/DASMA 108-2012 shows that testing of garage doors conducted in accordance with ANSI/DASMA 108-2005 can be considered at least equivalent to ANSI/DASMA 108-2012

Sincerely,



Scott Hamilton, P.E.
Florida P.E. #63286
Senior Project Engineer
Clipay Building Products Company