

Equivalence of Product Standards

For

FL 6508

DE # 380149

RE: Test Standard Equivalency Statement

Based on my evaluation of the standards relative to the evaluation reports in the above referenced Florida Product Approval:


- The UL 580-94 & UL 1897-98 standard version used to test the evaluated product assembly is equivalent with the prescribe standards in UL 580-06 & UL 1897-12 adopted by the Florida Building Code 7th Edition (2020).

Sincerely,

DANSCO ENGINEERING, LLC

This item has been digitally signed and sealed
by **Samuel A. Greenberg, PE** on **06/08/2021** using a
Digital Signature.

Printed copies of this document are not considered
Signed and sealed and the SHA authentication code
must be verified on any electronic copies.



Samuel a. Greenberg, PE
Fla. Reg. No. 34245
CA25948