

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

October 13, 2020

Mr. Robert Richardson
Entrematic
165 Carriage Court
Winston-Salem, NC 27105


Re: ASTM E1886 & E1996 comparisons
Project No. 20-001

Mr. Richardson:

The 7th Edition Florida Building Code (2020) refers to ASTM E1886 and ASTM E1996 Standards. Chapter 36 in the Building Code refers to ASTM E1886-12 or -13a, and ASTM E1996-12a, -14a, or -17. Chapter 46 in the Residential Code refers to ASTM E1886-12 or -13a, and ASTM E1996-02, 12a, -14a, or -17.

A review of these documents shows that Amarr garage doors that were tested in accordance with ASTM E1886-05 and/or ASTM E1996-05 or -09 will also meet the requirements of ASTM E1886-13a, and/or ASTM E1996-17.

Sincerely,



STRUCTURAL SOLUTIONS, P.A.*
Thomas L. Shelmerdine, PE
Florida PE #48579
President