

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

October 14, 2020

Mr. Robert Richardson
Entrematic
165 Carriage Court
Winston-Salem, NC 27105


Re: ASTM E330 Comparison
Project No. 20-001

Mr. Richardson:

The 7th Edition Florida Building Code (2020) refers to the ASTM E330 Standard. Chapter 36 in the Building Code refers to ASTM E330-02 or -14. Chapter 46 in the Residential Code refers to ASTM E330-14.

A review of these documents shows that Amarr garage doors that were tested in accordance with ASTM E330-02 will also meet the requirements of ASTM E330-14.

Sincerely,



STRUCTURAL SOLUTIONS, P.A.*
Thomas L. Shelmerdine, PE
Florida PE #48579
President