

STRUCTURAL SOLUTIONS, P.A.

Structural Engineering ■ Investigations ■ Consulting

October 9, 2008

Re: Amarr Garage Doors Test Procedures
Per ASTM E330-1990, E330-2002, DASMA 108-2002 and DASMA 108-2005
Project No. 08-001


To Whom It May Concern:

This letter addresses the procedures that Amarr Garage Doors uses to test garage doors for windload resistance, and compares those procedures with ASTM E330-1990, ASTM E330-2002, DASMA 108-2002 and DASMA 108-2005.

I have reviewed the test procedures described in ASTM E330-1990, ASTM E330-2002, DASMA 108-2002 and DASMA 108-2005, and I have personally witnessed the testing performed by Amarr Garage Doors since 1995. The various procedures used by Amarr Garage Doors since testing began in 1995 have all been in substantial conformance with the procedures described in these four documents.

All of these test procedures are essentially the same from an engineering standpoint. Therefore, doors that were tested in conformance with the earlier documents (i.e. ASTM E330-1990 and DASMA 108-2002) are considered to also comply with the later documents (i.e. ASTM E330-2002 and DASMA 108-2005).

Sincerely,



STRUCTURAL SOLUTIONS, P.A.
Thomas L. Sheffnerdine, PE