



January 30, 2024

Page 1 of 1

To: Product Approval Department
Florida Department of Community Affairs
2555 Shumard Oak Boulevard
Tallahassee, FL 32399-2100

RE: Equivalency Letter of FL-7274

To Product Approval Department:

This letter is concerning the Product Approval of the ArmorPanel Steel Roof Deck Panels manufactured by Frey-Moss Structures. The approval number was FL-7274-R3. The report number for the submittal was 63810.01-122-18. The expiration date for the approval was 12/31/23.

The purpose of this letter is to show the equivalency of the product, listed above, to the new codes. The current test report and approval was done under the 2004 Florida Building Code. The tests were done under ASTM E-1592 – 2001. A review of the 2020 Building Code was completed, and an equivalency letter was submitted and stated no changes were required in the fabrication or assembly of the product to meet the requirements of the 2020 code and the product received updated approval. In review of the 2023 Building Code, no changes are required in the fabrication or assembly of the product to meet the requirements of the new code. The testing as shown in the report is still valid under the 2023 Florida Building Codes and ASTM E-1592 – 05(2017).

Please contact Ed Dugan at 770-483-7543 Ext. 118 with any questions or concerns.

Thank you.

Charles H. Moss, P.E.
Florida License # 22891

