



April 9, 2026

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399


Regarding: Fenetex Corporation
Fenetex Hurricane Screens – FL #8637.1 – EX 23-62405
Impact Resistant Wind Abatement System

To Whom It May Concern:

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the Florida Building Code 8th Edition (2023); however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above-referenced building code.

Code Title	Tests Performed according to:	Current Equivalent Standard
Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials	ASTM E1886-02 or 05	ASTM E1886-13a or 19
Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes	ASTM E1996-06 or 09 or 12	ASTM E1996-17 or 14a or 20
Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference	ASTM E330—02	ASTM E330/E330M—14 or 14(2021)

Respectfully,



Digitally signed by
Frank Bennardo
Date: 2026.04.16
08:46:46 -04'00'

Frank Bennardo, P.E.
ENGINEERING EXPRESS®
#PE 0046549 | Cert. Auth. 9885