



October 17, 2023

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399

Regarding: Morgan Windows & Glass, Inc.
Series M3100I Fixed Window - Large Missile Impact Resistant - Non-HVHZ
FL #8649.1 – EX 23-68116a
Series M3100N Fixed Windows - Non-Impact Resistant Windows – Non-HVHZ
FL #8649.2 – EX 23-68116b

To Whom It May Concern:

This office has reviewed test reports showing structural performance of the above-noted product. These test reports pertain to testing performed in accordance with the referenced standards in the table shown below. These noted standards are not adopted in the Florida Building Code Eighth Edition (2023); however, for the purpose of determining the performance of the product, this standard is equivalent to the corresponding standards, which are adopted standards in the above referenced building code.

Code Title	Tests Performed according to:	Current Equivalent Standard
North American Fenestration Standard / Specifications for Windows, Doors, and Skylights.	AAMA/WDMA/CSA 101/I.S.2/A440-08	AAMA/WDMA/CSA 101/I.S.2/A440-17
Test Method for Performance of Exterior windows, Curtain Walls, Doors, and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials	ASTM E1886-02	ASTM E1886-19
Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes	ASTM E1996-02	ASTM E1996-20

Respectfully, 10/17/23



Frank L. Bennardo, P.E.
ENGINEERING EXPRESS®
#PE0046549 | Cert. Auth. 9885