

October 13, 2020

Sun Metals Systems, Inc
5008 Tampa West Boulevard
Tampa, FL 33634

Subject: FBC 2020 Equivalence of Product Standards
FL 9291
E1886, E1996

To Whom It May Concern:

The purpose of this document is to clarify that although E1886-05 is not in the 2020 Florida Building Code, it is an equivalent standard to the -2012 revision of the standard. Therefore, products tested according to E1886-05 are in compliance with the 2020 Florida Building Code.

In addition, this is also to clarify that although E1996-05 is not in the 2020 Florida Building Code, it is an equivalent standard to the -2017 revision of the standard. Therefore, products tested according to E1996-05 are in compliance with the 2020 Florida Building Code.

Let me know if you require any additional information.

Sincerely,



Gordon Thomas, P.E.
3759 Blossom Ct
Mason, OH 45040
Florida Registration # 46718

