

Prepared with Cooperation from:
Window Craftsmen Inc.
6031 Clark Center Avenue
Sarasota, FL 34238

December 10, 2020

Anchor Calculations:
Installation of Glass Sliding Doors
In Aluminum, Wood or Concrete, and Masonry Openings

Window Series:
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Reference: Test reports NCTL-210-3220-1, NCTL-210-3220-1B/W-1965

Testing Facility: Certified Testing Laboratories
7252 Narcoossee Rd.
Orlando, Florida 32822

Test Standards: AAMA/WDMA/101/I.S.2-97
AAMA/WDMA/CSA 101/I.S.2/A440-05
AAMA/WDMA/CSA 101/I.S.2/A440-08
TAS 202-94


Nami #: NI006690

Specimen: 192" x 96" Sliding Glass Pocket Door, XXXX pocket door configuration.

Glazing: 1/4" thick tempered glass

Design Pressure: +50PSF/-50PSF

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232



Digitally
signed by
Mark Smith
Date:
2020.12.10
06:23:03[®]
-05'00'

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Notes:

Anchor calculations are based on approved installation instructions and:

- 1) Concrete or masonry substrate where one by, non-structural, wood bucking is employed, use 1/4" ITW Tapcon anchors of sufficient length to achieve a minimum embedment of 1-1/4" into min. 2000 psi concrete or masonry.
- 2) Concrete substrate where wood bucking is not employed, use 1/4" ITW Tapcon anchors of sufficient length to achieve a minimum embedment of 1-1/4" into min. 2000 psi concrete or masonry.
- 3) Wood Frame substrate, use #12 wood screws of sufficient embedment of 1-1/2" into spruce pine, fir or equivalent strength wood framing.
- 4) Aluminum Frame substrate, #12 Tek screw of sufficient length to allow full thread engagement through aluminum. Reference Aluminum Design Manual, Allowable stress design, 5.4. Aluminum to be used is to be 6063-T5, equivalent or stronger.
- 5) Two (2) installation anchors are to be installed at each location except at hook strip. Hook Strips require one (1) installation anchor per anchor location.
- 6) Maximum allowable shim thickness shall be 1/4". A load bearing shim shall be located at each anchor.
- 7) Anchor calculations and analysis comply with the current Florida Building Code and including High Velocity Hurricane Zone.

Tested Installation Anchor Information

Fifty-eight (58) #12 x 1.75 Phillips flat head countersunk sheet metal screws, twenty-four (24) were located in the head and twenty-four (24) in the sill in two rows. Starting 6" max. from the end and spaced 16.25" on center. The Jamb had ten (10) #12 screws 6" from the top and 24.5" max. on center in two rows, and nine (9) #10 X 1.75 pan head screws on the hook strip, 6" from the end and 12.25" max. on center.

Anchors to be qualified:

1. #12 wood screws for installation in wood substrates.
2. 1/4" ITW Tapcons for installation in concrete and masonry substrates.
3. #12 Tek screws for installation into aluminum substrates.

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Anchor Calculations:

#12 wood screw
1-1/2" embedment

Allowable Bearing of 6063-T5 aluminum frame=
 $(F_{by}/1.65)(D)(t) = (16,000/1.65)(.218)(.062) = 131.6 \text{ lbs.}$

Head & Sill

Shear:

Proof load 80 ksi
Root diameter = .171 in.
Shear=459 pounds
Allowable shear under load with aluminum in wood is 133.6 pounds
NDS min lateral load in wood for #12 wood screw is 141 pounds

Bending:

Allowable bending stress=64 ksi
Cantilever=.250" , Moment arm=.125
Allowable bending load=254 pounds

Jamb

Shear:

Proof load 80 ksi
Root diameter = .171 in.
Shear=459 pounds
Allowable shear under load with aluminum in wood is 133.6 pounds
NDS min lateral load in wood for #12 wood screw is 141 pounds

Bending:

Allowable bending stress=64 ksi
Cantilever=.719" , Moment arm=.360
Allowable bending load=88 pounds

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Hook Strip

Shear:

Proof Load 80 ksi

Root diameter= .171 in.

Shear=459 pounds

Allowable shear under load with aluminum in wood is 133.6 pounds

NDS min lateral load in wood for #12 wood screw is 141 pounds

1/4" Tapcon

1-1/4" embedment

2000psi concrete

Allowable Bearing of 6063-T5 aluminum frame=

$(F_{by}/1.65)(D)(t) = (16,000/1.65)(.250)(.062) = 150.3 \text{ lbs.}$

Head & Sill

Shear:

Yield Strength = 92 ksi

Allowable shear= 285 pounds

Bending:

Root dia=.175

Allowable bending stress=73.6 ksi

Cantilever=.250", Moment arm=.125

Allowable bending load= 315 pounds

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Sill

Shear:

Yield Strength = 92 ksi

Allowable Shear = 285 pounds

Bending:

Root dia=.175

Allowable bending stress=73.6 ksi

Cantilever=.336" , Moment arm=.168

Allowable bending load= 234 pounds

Jambs

Shear:

Yield Strength = 92 ksi

Allowable shear= 285

Reduction Factor @ 1.5 spacing = 132 pounds

Bending:

Root dia=.175

Allowable bending stress=73.6 ksi

Cantilever=.719" , Moment arm=.360

Allowable bending load=110 pounds

Hook Strip

Shear:

Proof Load 92 ksi

Root diameter= .175 in.

Shear=285 pounds

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

#12 TEK Screw

Min .125" thick aluminum

Allowable Bearing of 6063-T5 aluminum frame=
 $(F_{by}/1.65)(D)(t) = (16,000/1.65)(.218)(.062) = 131 \text{ lbs.}$

Pullout: $K_s \times D \times t_2 \times F_{ty2} = (1.01)(.218)(.125)(16000/1.65) = 257 \text{ lbs}$

Head & Sill

Shear:

Proof load 80 ksi

Root diameter = .171 in.

Allowable shear stress 20 ksi

Shear=459 pounds

Shear shall not exceed the least of:

$2 \times F_{tu1} / x D \times t_1 / nu = (2)(22000)(.21)(.062/1.95) = 293 \text{ lbs}$

$2 \times F_{tu2} \times D \times t_2 / nu = (2)(22000)(.21)(.125/1.95) = 593 \text{ lbs}$

$4.2 \times ((t_2)^3 \times D)^{1/2} \times F_{tu2} / ns \text{ for } t_2 \leq t_1 \dots 4.2(((.125^3)(.21))^{1/2})(22000/3) = 618 \text{ lbs}$

$P_{ns} / 1.25 ns = 459 / (1.25 \times 3) = 122.4$

Bending:

Allowable bending stress=64 ksi

Cantilever=.250" , Moment arm=.125

Allowable bending load=254 pounds

Jamb

Shear:

Proof load 80 ksi

Root diameter = .171 in.

Shear=459 pounds

Shear shall not exceed the least of:

$2 \times F_{tu1} / x D \times t_1 / nu = (2)(22000)(.21)(.062/1.95) = 293 \text{ lbs}$

$2 \times F_{tu2} \times D \times t_2 / nu = (2)(22000)(.21)(.125/1.95) = 593 \text{ lbs}$

$4.2 \times ((t_2)^3 \times D)^{1/2} \times F_{tu2} / ns \text{ for } t_2 \leq t_1 \dots 4.2(((.125^3)(.21))^{1/2})(22000/3) = 618 \text{ lbs}$

$P_{ns} / 1.25 ns = 459 / (1.25 \times 3) = 122.4$

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

Bending:

Allowable bending stress=64 ksi
Cantilever=.719" , Moment arm=.360
Allowable bending load=88 pounds

Hook Strip

Shear:

Proof load 80 ksi
Root diameter = .171 in.
Shear=459 pounds

Shear shall not exceed the least of:

$$2 \times F_{tu1} / \phi \times D \times t_1 / \nu = (2)(22000)(.21)(.062/1.95) = 293 \text{ lbs}$$

$$2 \times F_{tu2} \times D \times t_2 / \nu = (2)(22000)(.21)(.125/1.95) = 593 \text{ lbs}$$

$$4.2 \times ((t_2)^3 \times D)^{1/2} \times F_{tu2} / \nu \text{ for } t_2 \leq t_1 \dots 4.2(((.125^3)(.21))^{1/2})(22000/3) = 618 \text{ lbs}$$

$$P_{ns} / 1.25 \nu = 459 / (1.25 \times 3) = 122.4$$

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

50R Glass Sliding Doors

Load on 192" header and sill:
Area=6,912 square in=48 square feet
Design pressure= 50psf
Total load = 2400 pounds

Load on 96" Jambs and hook strip:
Area=2304 square in=16 square feet
Design Pressure= 50psf
Total load= 800 pounds

Minimum Anchors required:

Spacing, Locations End Distance & # of Anchors/Location:

Head:	16.38"	12 Locations	6" End Distance	2 Anchor/Loc
Frame Jambs:	17.00"	6 Locations	5.5" End Distance	2 Anchors/Loc
Hook Strip:	11.00"	9 Locations	3.375" End Distance	1 Anchor/Loc
Sill:	16.38"	12Locations	6" End Distance	2 Anchors/Loc

Verify Anchor Locations Required exceeds # of Anchor Locations during Testing:

Head:	12 Locations Required =>	12 Locations Tested
Frame Jambs:	6 Locations Required=>	5 Locations Tested
Hook Strip:	9 Locations Required =>	9 Locations Tested
Frame Jambs:	12 Locations Required=>	12 Locations Tested

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
50R Glass Sliding Doors
Aluminum By-Pass/Center Meet/Pocket

#12 Wood Anchor:

Head Capacity:	3158 lbs.	>	2400 lbs.	OK
Jamb Capacity:	1056 lbs.	>	800 lbs.	OK
Hook Strip Capacity:	882 lbs.	>	800 lbs.	OK
Sill Capacity:	3158 lbs.	>	2400 lbs.	OK

Combined Bending plus Shear:

(fb/Fb)+(fv/Fv) =< 1.0 Fb=64 ksi Fv=20ksi
Head: (.393)+(.218)=.610<1.0 OK
Jamb: (.754)+(.146)=.900<1.0 OK
Sill: (.393)+(.418)=.610<1.0 OK
Hook Strip: (0)+(.194)=.194<1.0 OK

#1/4 Tapcon:

Head Capacity:	3600 lbs.	>	2400 lbs.	OK
Jamb Capacity:	1320 lbs.	>	800 lbs.	OK
Hook Strip Capacity:	846 lbs.	>	800 lbs.	OK
Sill Capacity:	3600 lbs.	>	2400 lbs.	OK

Combined Bending plus Shear:

(fb/Fb)+(fv/Fv) =< 1.0 Fb=64 ksi Fv=20ksi
Head: (.427)+(.351)=.778<1.0 OK
Jamb: (.613)+(.115)=.728<1.0 OK
Sill: (.427)+(.351)=.778<1.0 OK
Hook Strip: (0)+(.153)=.153<1.0 OK

Mark A. Smith, P.E.
Florida No. 55511
3738 Kingswood Drive
Sarasota, FL 34232

Window Craftsmen, Inc.
 50R Glass Sliding Doors
 Aluminum By-Pass/Center Meet/Pocket

#12 Tek Screw:

Head Capacity:	3158 lbs.	>	2400 lbs.	OK
Jamb Capacity:	1056 lbs.	>	800 lbs.	OK
Hook Strip Capacity:	882 lbs.	>	800 lbs.	OK
Sill Capacity:	3158 lbs.	>	2400 lbs.	OK

Combined Bending plus Shear:

$(f_b/F_b) + (f_v/F_v) \leq 1.0$ $F_b = 64 \text{ ksi}$ $F_v = 20 \text{ ksi}$
 Head: $(.393) + (.218) = .611 < 1.0$ OK
 Jamb: $(.754) + (.146) = .900 < 1.0$ OK
 Sill: $(.393) + (.218) = .611 < 1.0$ OK
 Hook Strip: $(0) + (.194) = .194 < 1.0$ OK

Conclusion:

Anchor Locations Required (192" X 96):

Spacing, Locations End Distance & # of Anchors/Location:

Head:	16-3/8"	12 Locations	6" End Distance	2 Anchor/Loc
Frame Jambs:	17"	6 Locations	5.5" End Distance	2 Anchors/Loc
Hook Strip:	11"	9 Locations	3.375" End Distance	1 Anchor/Loc
Sill:	16-3/8"	12 Locations	6" End Distance	2 Anchors/Loc

Mark A. Smith, P.E.
 Florida No. 55511
 3738 Kingswood Drive
 Sarasota, FL 34232

