

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

ENGINEER'S EVALUATION REPORT #WWS-226

Prepared for:

Palm City Millwork, Inc.
3313 S.W. 42nd Ave.
Palm City, FL 34990
Phone: 800-273-5598

Prepared by:

Warren W. Schaefer, P.E.
Florida Professional Engineer #44135

Manufacturer: Palm City Millwork, Inc.

Product Category: Doors

Evaluation Method: 1-D (Engineer's evaluation)

Product model & name: 10 Foot Out-swing Impact Wood Paneled Doors

Documents that must accompany this report:

1. W. W. Schaefer Engineering & Consulting drawing No. 1470B

Door size restrictions and assembly requirements:

See drawing No. 1470B

Maximum allowable design pressure:

See drawing No. 1470B

Installation requirements:

See drawing No. 1470B

Code compliance:

Code section(s) considered with this evaluation:

FBC Chapter 17

Wood Coatings:

All wood members shall be of an approved durable species or be treated in an approved method with an approved preservative per applicable codes and standards.

Mullions:

Mullion conditions stated in this approval have been tested in accordance with TAS-201, 202 & 203 and meet the requirements of FBC.

Test Standards applicable to the testing of these doors:

TAS-201, 202 & 203

Test Laboratory: Hurricane Test Laboratory, Inc.

Test report numbers: 0067-1014-06

General report notes & system limitations:

1. All size & installation conditions shown in this report and the referenced drawing No. 1470B are based off the referenced test reports and/or engineering analysis in accordance with the Florida Building Code.
2. Doors shall be constructed in accordance with the descriptions in this report, and the manufacturer's state approved quality assurance entity specifications.
3. This product is approved for use in & outside of the High Velocity Hurricane Zones (HVHZ).
4. Job required design wind pressure shall be calculated in accordance with the Florida Building Code Chapter 16 and ASCE 7 Minimum Design Loads for Buildings and Other Structures (0.85 directionality factor may apply per the current ASCE 7 standard).
5. These doors are both small & large missile impact rated for use in wind zone 4 & missile level "D" locations and need not be shuttered.

Quality Assurance Entity: Architectural Testing, Inc. (ATI)

JAN 08 2015

Warren W. Schaefer, P.E.
Florida P.E. #44135

