



Specialty Engineering Services & Solutions, LLC

18540 126th Terrace North, Jupiter, FL 33478

M: 561-412-8287

Jeffrey.friant@specialtyengineeringservices.com

www.sess-inc.com

Certificate of Authorization #32371

August 25, 2025

Supplemental Fire Rating Tests

Application Number: FL11291-R13 (Revision)

SESS Project Number: 25-3245

For: Storm Smart Industries, LLC
6182 Idlewild Street
Fort Myers, FL 33966

To: Florida Department of Business and Professional Regulation
1940 North Monroe Street, Tallahassee, FL 32399

Regarding: Storm Catcher Wind Abatement System, Product Approval Application

To whom this letter concerns,

This office has reviewed supplemental fire-rating testing performed by HETI (Test Reports HETI-17-F301, F302, F303, F304, F305 corresponding to black, white, gray, brown, and bone colored fabric respectively, 2017 testing). Tests were conducted in accordance with ASTM D1929-14, D2843-10, and D635-14 for self-ignition, smoke density, and rate of burn.

Additionally, sufficient information has been provided to certify the ASTM G154-16 and G155-13 UV requirements (REF: Tencate fabric test report 10/24/13 et. al)

This letter is to confirm that the fabric tested as per above is approved per Miami Dade HVHZ requirements for the product as listed in FL11291. This letter is to be considered when applying for a Local Product Approval in accordance with FS 553.8425 utilizing the FL HVHZ approval along with the test reports listed above as a certification for use within the HVHZ utilizing this equivalent fabric but without the additional FR additive.

Except as expressly provided herein, no additional certifications or affirmations are intended. Final approval shall be at the discretion of the governing authority having jurisdiction as inspection of work completed will be performed by others. Unless otherwise noted herein, all specifications and installation shall follow the product approval referenced above as well as the minimum requirements of the Florida Building Code Eighth Edition (2023).

Respectfully,

Jeffrey Friant, P.E. 60974

 Digitally signed by Jeffrey Friant, P.E. 60974
Date: 2025.08.25 08:16:03 -04'00'

Jeffrey C. Friant, P.E. FL#60974
Owner
Specialty Engineering Services & Solutions
Jeffrey.Friant@Specialtyengineeringservices.com

August 25, 2025

A valid PE seal is required for certification